



STAR GRACE CHEMICAL PTE LTD

ADD: 73 UPPER PAYA LEBAR ROAD #06-01C CENTRO BIANCO Singapore 534818

E-mail:maggiewang@stargrace-chemical.com Web: www.stargrace-chemical.com

TEL:+86-411-3901-3010 TEL: +86-411-3904-9790

CERTIFICATE OF ANALYSIS

PRODUCT: Refrigerant R143a

THIS IS CERTIFY THAT WE, THE UNDERSIGNED HAVE INSPECTED THE QUALITY OF THE ABOVE MENTIONED GOODS AND FOUND THE RESULT OF INSPECTION AS FOLLOWS:

Appearance	Colorless transparent liquefied gas
Purity, %	≥99.5
Water, %	≤0.002
Acidity (as HCl), %	≤0.0001
Evaporation residue, %	≤0.005
Non-condensable gas volume fraction (25°C), %	≤1.5
Chloride (Cl-) test	Pass

QUALITY CONTROL DEPT. MANAGER: L. Mai



Maggie Wang